

Department:	Comments:
FIRE	No comments
PW/E	No issues
InspSvcs	No comments
ESP	The only gas line in the area that could be affected is the gas service to Jaco's. It runs from the median on Palafox straight to the gas meter and it appears new sprinkler lines will be installed over this area. This should be caught with the 811 locate ticket.
ECUA	No comments
GPW	No comments
ATT	No comments
Surveyor	Planning Board Application Project Address is listed as "600" South Palafox. This information should be confirmed. Unable to locate the benchmarks on the civil plans. This civil plans need to include at least two benchmarks for construction.
Planning	No comments
GIS	Project address should be 900 S. Palafox St.