

Project: Magee Field Vacation of ROW

Department:

Comments:

FIRE	No comments.
PW/E	No comments.
Insp Svcs	No comments.
ESP	No comments.
ECUA	ECUA owns and operates an 8" sewer main and an 8" water main within the area of Yonge St that is proposed to be vacated. Therefore, ECUA will need to retain a full length and width utility easement for the area to be vacated. Additionally, we'd like to mention that ECUA will need 24-hour access to its facilities and, not knowing the depth of the sewer, we will need to be sure there are adequate building setbacks, should the City want to construct a building.
FPL	No comments.
ATT	No comments.
Surveyor	No comments.
Planning	No comments.